


April, 2000


Series 67 Fitting Change

In October 1999, McDonnell & Miller changed the attachment hardware on the Series 67 Low Water Cut-Off. The change involved replacing the special compression fitting located in the upper gauge glass tapping with a standard tee and compression fitting. The graphic below shows an exploded drawing of the current design, and another of the change.

Original Design (*Before October 1999 & After February 2000*)



Design Change (*Implemented from October 1999 through February 2000*)



The intent of this change was to standardize components on the production floor thus further improving our on-time shipping ability. However, we received several complaints from OEMs and contractors in the field that the change has made installation difficult. As a result, **we reverted back to the original design at the end of February 2000.**

The following date codes for all Series 67 products were affected by this change:

99K	October-99	00A	January-00
99L	November-99	00B	February-00
99M	December-99		

(over)

Replacement tube assemblies SA66-35 (344100) reflecting the original design are available. Call your Customer Service Representative or Steve Mueller if your customers need "original design" tube assemblies. We will provide them at no charge.

We apologize for any inconvenience this change may have caused. If you have any questions or concerns, please call me.

Sincerely,

Jerry McCallum
Product Line Manager